



EMRS DUMBRIGUDA

DUMBRIGUDA, ASR (DISTT.) A.P.-531151

(Under Ministry of Tribal Affairs-MoTA, GoI)

CBSE AFFILIATION No: 120015

U-DISE No: 28130403207

PHONE NO: +918936249466

SCHOOL NO: 59354

E-MAIL ID: emrsdumbriguda@gmail.com

School Website: www.emrsdumbriguda.org.in

F.No.44/CBSE/EMRS Dumbriguda/2026-2027/713

Date: 09.04.2026

To

The Regional Officer,
Central Board of Secondary Education (CBSE),
Regional Office, Vijayawada

Sub: Regarding Fire Safety Certificate for Extension of CBSE Affiliation for Eklavya Model Residential School, Dumbriguda (School No. 59354)

Ref: Rc. No. 596/MSB Section/DGFS/2017, dated 07.12.2017, issued by the Director General, State Disaster Response and Fire Services, Vijayawada, Andhra Pradesh

Sir/Madam,

With reference to the subject cited above, it is submitted that the building of Eklavya Model Residential School, Dumbriguda (School No. 59354) is less than 6 meters in height. As per the guidelines issued by the competent authority mentioned in the reference, buildings of such height do not require a Fire Safety Certificate.

In view of the above, I request you to kindly acknowledge the same and take necessary action accordingly.

With regards,

Yours faithfully,


09/04/26

PRINCIPAL
(Dr. S.K. Singh)
Principal

Eklavya Model Residential School
Dumbriguda, A.S.R. Dist., A.P.

CBSE Affiliation No: 120015 • Code: 59354

Enclr: Rc. No. 596/MSB Section/DGFS/2017, dated 07.12.2017, issued by the Director General, State Disaster Response and Fire Services, Vijayawada, Andhra Pradesh – 1 Page.

Copy to:

1. The Commissioner, NESTS, HQ, New Delhi – for kind information, please.
2. The Secretary, APTWREIS (Gurukulam), Tadepalli – for kind information and necessary directions to the concerned, please.
3. Shri G. Krishna Rao, Consultant, NESTS, Andhra Pradesh – for kind information, please.
4. Office Copy.


09/04/26

PRINCIPAL

Eklavya Model Residential School
Dumbriguda, A.S.R. Dist., A.P.

CBSE Affiliation No: 120015 • Code: 59354



GOVERNMENT OF ANDHRA PRADESH
STATE DISASTER RESPONSE AND FIRE SERVICES DEPARTMENT

From,
Director General,
State Disaster Response and Fire Services,
Andhra Pradesh, Vijayawada.

To,
The Special Chief Secretary to
Government, A.P. Secretary Office,
School Educational Department,
4th Block-1st Floor,
Velagapudi, Amaravathi.

Re.No.596/MSB Section/DGFS/2017, Dated 07-12-2017.

Sir,

Sub: A.P. State Disaster Response & Fire Services Department-Vijayawada-MSB Section- Issue necessary directions to the concerned authorities on the Educational Institutions which have not come under Section (13) of A.P.F.s act, 1999 i.e., less than 500 Sq Mtrs., in Plot area (or) less than 06.00 Meters height of Buildings (G+1) like Schools and Colleges are not required Fire NOC-Intimation-Regarding .

Ref: This Office Re.No.596/MSB Section/DGFS/2017, Dated 03-07-2017.

<< 0 >>


In continuation of this Office reference 1st cited, it is to inform that, all the Educational Institutions like Schools and Colleges which are less than 500 Sq Meters in Plot area (or) less than 06.00 Meters in height of the Building of Ground Floor + 1st Floor only are not required to take Fire No Objection Certificates from this Department.

2) However, keeping in view of the Safety of the School Children the following Fire Safety Measures shall be ensured by taking self declaration from the concerned School Principal / Head Master.

- i) Minimum (2) Extinguishers of ABC Type shall be provided in the Premises
- ii) Minimum (2) Sand Buckets and (2) Water Buckets shall be having to a stand in the premises.

3) Submitted for favour of kind information and necessary action.

Yours sincerely,


DIRECTOR GENERAL,
State Disaster Response and Fire Service,
Andhra Pradesh, Vijayawada.

Copy to:

All District Educational Officer, concerned for information.
The Regional Fire Officer, Southern Region & Eastern Region, Vijayawada.
All District Fire Officers and Asst., District Fire Officers in the State.
All Station Fire Officers in the State.

Scanned with CamScanner



Scanned with OKEN Scanner